सत्यमेव जयते

Government of West Bengal

Office of the Divisional Fire Officer

West Bengal Fire & Emergency Services

Ghoshpara Road, P.O.:- Bengal Enamel, Pin :- 743122

Memo No.: FSR/FS/N24PGSDIVN./193/16/(120/16) **Date : 28-02-2026**

From :
Divisional Fire Officer
North 24 Parganas Division,
West Bengal Fire & Emergency Services

To :
BHARATI VIDYA MANDIR (BVM)
97/213/327, DANGAPARA ROAD, R.S. DAG NO.- 132,135,136, R.S. KHAITAN NO.- 263, J.L NO.-3, R.S. NO.-61, TOUZI NO -184-190, MOUZA - RAHARA, WARD N0 - 2 (OLD3), P.S, MUNICIPALITY- KHARDAH, DIST.-24 PGS (N), KOLKATA-700118

Sub : Renewal of Fire Safety Certificate for an existing construction of "G +II" storied building under group of Educational in the name & style of "BHARATI VIDYA MANDIR (BVM)" At the premises no-97/213/327, Dangapara Road, P/S-Khardah, Ward No-2 Under Khardah Municipality, Mouza-Rahara, J.L No-3, R.S Dag No-132,135,136, R.S No-61,R.S Khatian No-263, TOUZI NO-184-190, Dist.-North 24 Parganas,Kolkata-700118.

This is in reference to your AIN 211912606300009779 dated 24-Feb-2026 regarding Renewal of Fire Safety Certificate for an existing construction of "G +II" storied building under group of Educational in the name & style of "BHARATI VIDYA MANDIR (BVM)" At the premises no-97/213/327, Dangapara Road, P/S-Khardah, Ward No-2 Under Khardah Municipality, Mouza-Rahara, J.L No-3, R.S Dag No-132,135,136, R.S No-61,R.S Khatian No-263, TOUZI NO-184-190, Dist.-North 24 Parganas,Kolkata-700118.

.

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the **Renewal of Fire Safety Certificate** for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated maintained.

Recommendation:

Digitally signed by HP
Date: 2026.09.29 17:40:44 +05:30
Reason: reason
Location: location

The authe... erified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verificatio... link and keying in the Unique Number : 211912606300009779

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing of the Fire Safety Certificate for occupancy of the aforesaid building.

However, to keep-up the Fire Safety Measure of the aforesaid building the following safety measure need to incorporated/maintained.

1. Drive away must be free from any type of obstruction for easy movement of Fire Appliances. No parking shall be allowed on the drive away.
2. Directional sign and escape route shall be displayed prominently.
3. The interior finish decoration of the building shall be made with low flame spread materials conforming to IS specification.
4. To eliminate risk of the fire hazards, good house- keeping both for inside and outside of the building shall be maintained.
5. Existing electrical wiring of the whole building shall have to be carefully checked for anywhere and tear in them, particularly lines above false ceiling and ducts.
6. A fire control room including a close circuit T.V. system will have to be maintained which all floor of the building.
7. The Notice of fire Fighting and evacuation with" EXIT SIGN "from the building shall be prepared and displayed at all vulnerable of the building.
8. The employee and security staff shall be conversant with installed Fire Fighting equipment's of the building and to operate in the event of fire and testing.
9. Mock Fire practice and Evacuation Drill shall be performed with all participants at regular interval.
10. Transformer and switch gear room shall be protected with automatic CO2 or DCP Fire Extinguisher conforming I.S. specification.
11. A crew of trained Fireman under an experienced officer shall be maintained round the clock basis.
12. First Aid firefighting system shall be provided as per I.S. specification.
13. Arrangement shall have to be made for regular checking, testing, and maintenance of all the Fire Fighting installation in the building to keep them in perfectly good working condition at all the times.
14. If required the old line shall have to be replace with new lines the cable shall always be laid in M.S. conduct pipes continuously bonded to the earth.
15. The Fire Safety Audit to be conducted a regular interval and to be recorded to the Fire Prevention maintenance regular.
16. This Final of FSC is valid for three years and have to be renewal after three years from the date of issue of this letter.
17. After three years such as Certificate is to be obtained from The Director General, West Bengal Fire & Emergency Services performance of all the life & Fire safety arrangement and installation of the building.
18. Periodical flashing of the water from the hydrants and Hose reel Hose pipe Line shall be made to maintain the efficient working performance of the above-mentioned system.
19. No Addition & Alteration without prior permission from The Director General, West Bengal Fire & Emergency Services, Otherwise the Fire Safety Certificate will be treated as cancelled.

Valid Upto : 26-Feb-2029

Signature valid

Digitally Signed.
Name: SAROJ KUMAR BAG
Date: 10-Mar-2024 19:50:24
Reason: D-Sign
Location: E-Dist 2.0

Divisional Fire Officer

West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912606300009779